



ATTESTATION OF CONFORMITY

No. 74100365-ETD 11-0829

Issued to: Betronic Solutions B.V., Pedro de Medinalaan 11,1086 XK Amsterdam NL

For the product: Femtogrid solar inverter

Trade name: Femtogrid® inverter 2200

Type/Model: Solar inverter 2200ISO1

Ratings: Input: 360..400 Vdc, 6,7 A max, 0-2550 W
Output: 230 Vac, 50Hz, 10,5 A, 2400 W max

Manufactured by: Betronic Solutions B.V., Pedro de Medinalaan 11,1086 XK Amsterdam NL

Requirements: NEN-EN 50438:2008 Requirements for the connection of microgenerators in parallel with public low-voltage distribution networks.

Interface protection only examined for the following country specific requirements:

- Belgium
- Germany, including requirements defined in VDE0126:2006-02
- Spain, including requirements defined in RD1663:2000-09
- France
- United Kingdom, including requirements defined in G83/1:2003-9
- Italy
- The Netherlands

This Attestation is granted on account of an examination by KEMA, the results of which are laid down in a confidential file no. 74100365-ETD 11-0828, d.d. 29-04-2011

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA

KEMA
Arnhem, date 29-04-2011

Dr. Erik de Jong
Project Manager

©Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands
T +31 26 3 56 20 00 F +31 26 3 52 58 00 customer@kema.com www.kema.com Registered Arnhem 09085396